

Manual Supplement

Manual Title:	7381 Users Guide	Supplement Issue:	5
Print Date:	June 2013	Issue Date:	1/19
Revision/Date:		Page Count:	1

This supplement contains information necessary to ensure the accuracy of the above manual.
This manual is distributed as an electronic manual on the following CD-ROM:

CD Title:	7381
CD Rev. & Date:	11/2013
CD PN:	3750899

Change #1

On page 12, after the last bullet in the **Environmental Conditions** section, add:

Note

The Product can show some control sensitivity to moderate or severe electromagnetic fields or conducted interference of certain frequencies. In the presence of radiated EM disturbances, with frequencies of 250 MHz to 400 MHz and with amplitude >1 V/m to a maximum of 3 V/m, add 0.0025 °C to the stability specification. Stability is not guaranteed if amplitude is >3 V/m. When subject to conducted disturbances of 8 MHz to 80 MHz, and amplitude >3 V, add 0.005 °C to the stability specification.

Change #2, 154

On page 18, replace **5.3.2** paragraph, with:

5.3.2 Installation On A Concrete Floor

Using a concrete drill and concrete drill bit, drill three 1/4 inch x 1 3/4 inch deep (approximately 6.5 mm x 32 mm) holes in the concrete floor using the bracket to mark the hole placement. Drop the flare anchor bolt into the hole. Tightening the screw expands the anchor in the drilled hole and secures the bracket. Ensure that the bracket is installed in such a way as to ensure the bath will have a minimum of 6 inches of clearance for air circulation (See Figure 2). Screw the bracket securely to the floor.

Change #3, 514

On page 12, under the **Environmental Conditions**, replace the 1st and 2nd bullets with:

- temperature range: 5 °C to 35 °C (41 °F to 95 °F)
- ambient relative humidity: maximum 80 % for temperatures <31 °C decreasing linearly to 50 % at 35 °C

Change #4, 552

On page 13, under **4.1 Unpacking**, delete the 8th bullet.

Change #5, 640

On page 11, under **Specifications**, replace the **Refrigeration** row with:

Refrigeration R-410A first stage, R-508b second stage,

On page 36, under **8.6 Refrigeration**, change:

From: R-507

To: R-410A